



District Level Water Analysis Laboratory

Uttar Pradesh Jal Nigam, (Rural), Fatehpur

TEST REPORT (WATER)

Report No:	FTP/JUN/1341	Date:	19/06/2023			
Customer details						
Office Name and Address:	Kendriya Vidyalaya Madhupuri In The Compus Of Govt Inter College, Fatehpur					
Basic details of sample						
District:	Fatehpur	Block;	Telyani			
Gram Panchayat / Town :	Fatehpur	Village/ City:	Fatehpur			
Habitation:	Abunager , Fatehpur	Location:	Abunager , Fatehpur			
Water Source:	Hand Pump	Sample no:	01			
Quantity of Sample:	2.0 Litter	Date of S.C.:	17/06/2023			
Receiving Date:	17/06/2023	S. Collector:	Manoj Kumar			
Sample Depositor:	Manoj Kumar					
Analysis Start Date:	19/06/2023	Analysis Completion Date:	19/06/2023			
Technical Date of Analysis						
S .No.	Analysed Parameters	Observed Value	Specified Values as Per BIS 10500:2012		Ref. Method Of Analysis	
			Acceptable Limit	Permissible		
1	2	3	4	5	6	
1	PH	7.11	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2012 (Electrometric Method)	
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025(Part 05): 2012	
3	Turbidity (NTU)	1.12	1	5	Is 3025 (Part 10):2012	
4	TDS (Mg/L)	1382	500	2000	IS 3025 (Part 16): 2008	
5	Chloride (Mg/L)	290	250	1000	Is 3025 (Part 32): 2014	
6	Total Alkalinity (Mg/L)	332	200	600	Is 3025 (Part 23): 2008	
7	Total Hardness (Mg /L)	240	200	600	Is 3025 (Part 21): 2009	
8	Fluoride (Mg/L)	1.12	1	1.5	Is 3025 (Part 60): 2008 (Electro. Chem. Probe Meth.	
9	Sulphate (MG/L)	126	200	600	Is 3025 (Part 24): 2009	
10	Nitrate (MG/L)	18	45	No Relaxation	Is 3025 (Part 34): 2009	
11	Iron (MG/L)	0.1	0.1	0.3	Is 3025 (Part 53): 2009	
These Parameters are out of NABL Scope, BDL- Below Detection limit, NT- Not Tested						
Note	1. This certificate refers only to the particular sample (S) submitted for testing.					
	2. This certificate shall not be reproduced , except in full , unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.					
	3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.					
	4. sample will be stored up to 15 days (in case of non perishable items only) from the date of issue.					
	REPORT PREPARED BY- Anuj Kumar			Authorized Signatory- Ranvijay Singh		

Laboratory E-Mail Id | districtlevelwateranalysislabo@gmail.com | Contact No | 7318317271

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No.

1147 / W-13)28

Dated: 26-06-2023

It is certified that an inspection team headed by ..Amurag Dubey.....Sampling Assistant (outsourcing)
 (Name of Officers with designation) from Division office, U.P. Jal Nigam (Rural), Fatehpur
 (Name of Department/ Office) inspected the Kendriya Vidyalaya madhupuri Fatehpur
 (Name & Address of the school) on19/06/23.....(date of inspection) and found that the
 Kendriya Vidyalaya madhupuri Fatehpur (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of ...one year.....

Signature with Seal:  Executive Engineer.....
 Div. Off. U.P. Jal Nigam (Rural)

Name : Ex. Fatehpur

Designation : Executive Engineer...

Name & Address of the Office / Department : Sadipur, Fatehpur

To,

.....The principal.....

.....K.V. madhupuri, Fatehpur

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.